

Lucrarea033 Alimentare apa si canaliz MAIA

**LISTA CUPRINZAND CANTITATILE DE UTILAJE  
SI ECHIPAMENTE TEHNOLOGICE, INCLUSIV DOTARILE**

Nr. crt.	Cod Denumirea Furnizorul (denumire, adresa, telefon, fax)	U/M	Cantitatea	Pretul unitar	Valoarea (exclusiv TVA)	Fisa tehnica atasata
0	1	2	3	4	5 = 3 X 4	6
1	<b>Obiect</b>	<b>01</b>	<b>Front captare</b>			
	a) Utilaje si echipamente tehnologice, cu montaj					
	<b>ES10</b>	BUCATA			<b>1,00000</b>	
	ELECTROPOMPA SUBMERSIBILA 10 MC/H, H = 10 MC/H					
	<b>ES2</b>	BUCATA			<b>4,00000</b>	
	ELECTROPOMPA SUBMERSIBILA 2,52 L/S, H = 30 MCA					
	<b>TDAM</b>	BUCATA			<b>1,00000</b>	
	TABLOU DISTRIBUTIE AUTOMATIZARE MONITORIZARE					
	<b>TNTC</b>	BUCATA			<b>1,00000</b>	
	TRADUCTOR DE NIVEL CU TRANSMITERE CONTINUA					
	<b>TP</b>	BUCATA			<b>1,00000</b>	
	TRADUCTOR DE PRESIUNE					
<b>TOTAL obiect01</b>		<b>Front captare</b>				
2	<b>Obiect</b>	<b>03</b>	<b>Gospodaria de apa</b>			
	a) Utilaje si echipamente tehnologice, cu montaj					
	<b>CPM</b>	BUCATA			<b>1,00000</b>	
	CARUCIOR CU PALAN MANUAL 1TF					
	<b>DCL</b>	SET			<b>1,00000</b>	
	INSTALATIE DOZARE CLOR GAZOS, CAPACITATE 5-100 G/H					
	<b>EPE1,8</b>	BUCATA			<b>1,00000</b>	
	ELECTROPOMPA SUBMERSIBILA DE EPUISMENT Q=1,8 MC/H					
	<b>EPI5</b>	BUCATA			<b>1,00000</b>	
	ELECTROPOMPA CENTRIFUGALA PT INCENDIU Q=5 L/S					
	<b>GP11,8</b>	SET			<b>1,00000</b>	
	GRUP POMPARE 3 ELECTROPOMPE Q GRUP= 11,8 L/S					
	<b>RE</b>	BUCATA			<b>2,00000</b>	
	RADIATOR ELECTRIC					
	<b>VACL</b>	BUCATA			<b>2,00000</b>	
	VENTILATOR AXIAL PROTEJAT CONTRA SCAPARILOR DE CL GAZOS					
	<b>VEM</b>	BUCATA			<b>1,00000</b>	
	VANA ELECTRICA/VANA MECANICA P =1,1 KW, U=24 V					
	c) Dotari, inclusiv utilaje si echipamente indep					
	<b>CCC</b>	BUCATA			<b>1,00000</b>	
	COMPUTER IN CONFIGURATIE COMPLETA					
	<b>EP</b>	SET			<b>3,00000</b>	
	ECHIPAMENT PROTECTIE					
	<b>IMP</b>	BUCATA			<b>1,00000</b>	
	IMPRIMANTA					
	<b>MC</b>	BUCATA			<b>1,00000</b>	
	MASA PENTRU COMPUTER					
	<b>S1</b>	BUCATA			<b>1,00000</b>	
	SOFT					
<b>TOTAL obiect03</b>		<b>Gospodaria de apa</b>				

Executant	01	Obiectiv	033			
0	1	2	3	4	5 = 3 X 4	6
3	<b>Obiect</b>	<b>05</b>	<b>Sistem canalizare</b>			
	a) Utilaje si echipamente tehnologice, cu montaj					
	<b>GP2</b>	SET		<b>2,00000</b>		
	GRUP POMPARE CU 2 POMPE SUBMERSIBILE QPOMPA = 9,44 L/S					
	<b>VA140</b>	BUCATA		<b>2,00000</b>		
	VENTILATOR AXIAL Q = 140 - 450 MC/H					
<b>TOTAL obiect05</b>		<b>Sistem canalizare</b>		<b>Total P:</b> _____		
				:		

PROIECTANT